

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : January 26, 2024

TO : John Tillotson, General Manager

FROM: Nicholas Pomeroy, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 2/15/2024**

- For the month of December the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filters and the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station: Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- Staff installed new upgrade kits for the return sludge and wasting pumps. These kits are designed to run more efficiently and not get clogged up with rags.
- Some of the parts for the bar screen repair have arrived on site. It is tentatively scheduled to be repaired the week of Feb 12th.
- Lift Station 14: Staff has been water flushing bi-weekly at lift station 14. Staff has also been doing a caustic flush on a monthly basis to help alleviate the hydrogen sulfide. Staff is also testing and recording the hydrogen sulfide numbers 2-3 times a week.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of Staff is gearing up to commence cleaning the collection system down in Plumas Lake area.
- The Waste Water Plant processed for the month of November was 49.57 million gallons, which is an average of 1.60 MGD flow.

If you have any questions my contact info is below.

Nicholas Pomeroy

Chief Plant Operator
Olivehurst Public Utility District
Phone (530) 743-0843
Cell (530) 635-8113
email: npomeroy@opud.org