

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : July 26, 2023

TO : John Tillotson, General Manager

FROM: Nicholas Pomeroy, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 8/17/2023**

- For the month of June the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filters and the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- Lift Station 14; Staff has been water flushing once a week at lift station 18. This has been very positive. The H2S numbers have dropped dramatically and stabilized. Staff believes that the main cause has been found and that is the force main going under the Highway 70. So by flushing lift station 18 it keeps the H2S (odors) down. We need time to see how much and how often we will need to do the flushing to keeping the odors to a minimum.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of Staff is gearing up to commence cleaning the collection system down in Plumas Lake area.
- Plant processed for the month of June was 48.47 MG which is an average of 1.61 MGD flow.

If you have any questions my contact info is below.

Nicholas Pomeroy

Chief Plant Operator
Olivehurst Public Utility District
Phone (530) 743-0843
Cell (530) 635-8113
email: npomeroy@opud.org