

OLIVEHURST PUBLIC UTILITY DISTRICT, 2026

To: John Tillotson

From: Virgil Willard

Re: Monthly Report on Activities June 2026

1. Water Treatment Plants / Wells:

- WTP #4 / Wel l#1 – No operating issue. June total: 0.183 MG
- WTP #28 / Well #10 – No operating issues. June total: 35.443 MG
- Wheeler Ranch WTP Well #29 and #30 – No operating issues. June total: 58.745 MG
- Lindhurst Booster Pump Station – No operating issues.
- Plumas Lake WTP Well #31 and Well #32 – No operating issues. June total: 62.402 MG
- WTP #34 – The plant is online with no operating issues. June total: 26.453 MG

2.

Total MG	2018	2019	2020	2021	2022	2023	2024	2025	2026
Jan	49.5	49.3	52.7	62.0	59.7	62.7	61.71	66.78	65.23
Feb	47.25	44.8	56.2	57.4	68.8	64.25	56.04	58.05	60.79
Mar	51.2	52.9	74.2	74.5	109.9	61.89	68.16	72.12	101.06
Apr	65.1	70.0	93.8	114.5	101.3	81.61	86.31	101.52	106.93
May	116.9	104.3	142.2	162.6	140	124.93	143.2	161.38	131.16
Jun	151.8	151.5	165.4	162.4	157	155.39	189.5	188.60	183.22
Jul	171.4	168.3	186.9	182.2	185	190.12	203.5	212.42	
Aug	152.1	170.9	176.9	165.5	102	188.11	181.2	184.53	
Sep	131.2	136.8	145.0	147.6	144	154.01	163.5	160.48	
Oct	105.2	117.2	132.3	109.3	125	117.66	148.0	109.01	
Nov	80.7	91.2	83.3	62.2	42	82.658	80.90	72.589	
Dec	53.5	60.5	62.3	58.3	62	71.571	76.46	56.064	

The pumping report will be a month behind

3.

Water Wells	Static June	Static July	Op June	Op July	Setting	GPM
Well #1	25ft	28ft	53ft	46ft	140ft	1500
Well #4	28ft	30ft	50ft	150ft	140ft	2300
Well #10	50ft	31ft	78ft	70ft	160ft	1500
Well #28	46ft	30ft	82ft	155ft	200ft	2400
Well #29	29ft	38ft	196ft	190ft	252ft	2450
Well #30	24ft	35ft	170ft	110ft	190ft	2600
Well #31	24ft	27ft	28ft	28ft	330ft	2500
Well #32	27ft	44ft	133ft	140ft	180ft	2909
Well #34	23ft	24ft	54ft	74ft	200ft	1300

4. For the month of June and July the distribution system and water treatment plants met all requirements.
5. Water Distribution Repairs
6. Radio Read Meters

- 45 meter locations on MXUs have been tested and repaired
- 0 flow checks evaluated and discussed with customers

Below is a list of repairs/expenditures recognizing failure after the monthly meter read.
June meter repair is \$33,455. The meter expenditure will be an addition to all monthly Water Department reports.

- 0 locations on Non-Consumption list repaired as necessary
- 200 MXU replaced (200 x \$165) = \$33,000
- 5 registers replaced (5 x \$75.00) = \$375
- 2 chambers replaced (2 x \$40.00) = \$80

7. Meter Program 0 flat rate services.
8. Water service shut off for non-payment - 97
9. District Subdivision and other projects
 - a. March/April finals:
Plumas Lake – 24
Olivehurst – 4