

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : March 28, 2024

TO : John Tillotson, General Manager

FROM: Nicholas Pomeroy, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 4/18/2024**

- For the month of February the Wastewater Treatment Facility had some exceedances of its N.P.D.E.S. permit. Mainly minimum Ultra Violet Transmittance percentage and Filter Turbidity daily average. These were all caused by the heavy rainfall and storms we had over multiple days.
- Plant Staff cleaned the filters and the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station: Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- The bar screen has been running for just over a month now. There haven't been any issues since the bar screen has been repaired.
- Lift Station 14: Staff has been water flushing bi-weekly at lift station 14. Staff has also been doing a caustic flush on a monthly basis to help alleviate the hydrogen sulfide. Staff is also testing and recording the hydrogen sulfide numbers 2-3 times a week.
- The sewer Camera Van has been sent to U-Rock to have a new camera system installed. We should have it back sometime in the middle of April and will start using it to inspect the sewer lines in Olivehurst first.
- The annual collections report has been completed and turned in to the state.
- Gold Village waste water plant has been running smoothly. There were no violations from February.
- The Hard Rock casino waste water plant has been running without any issues.
- The Waste Water Plant processed for the month of February was 76.44 million gallons, which is an average of 2.64 MGD flow.

If you have any questions my contact info is below.

Nicholas Pomeroy

Chief Plant Operator
Olivehurst Public Utility District
Phone (530) 743-0843
Cell (530) 635-8113
email: npomeroy@opud.org