

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : April 29, 2021

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 5/20/2021**

- For the month of April the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been check all equipment at Rio Del Oro lift station on a regular basis.
- Staff is continuing to put work into looking for I&I problems with the collection system. At this time most of that work is being done on the old systems here in Olivehurst area. Repairs are being done as the County proceeds with doing the road over lays.
- Estimated Plant processed for the month of April was 42.2 MG.