

# OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : May 28, 2021

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 6/17/2021**

---

- For the month of May the Wastewater Treatment Facility had one exceedances of its N.P.D.E.S. permit. 2.25 MPN/100 seven day median Permit is 2.2.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been check all equipment at Rio Del Oro lift station on a regular basis. The blower unit on the mini phoenix broke down and is being repaired. Should be back up and running first week of June.
- Staff is continuing to put work into looking for I&I problems with the collection system. At this time most of that work is being done on the old systems here in Olivehurst area. Repairs are being done as the County proceeds with doing the road over lays. 11<sup>th</sup> street has started and we have 5 repairs being done there.
- Estimated Plant processed for the month of April was 43.9 MG.