

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : November 23, 2021

TO : John Tillotson, General Manager


FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 12/16/2021**

- For the month of October the Wastewater Treatment Facility had one exceedances of its N.P.D.E.S. permit UV Transmittance. Caused by the October 24th storm. The Plant was in violation for two and a half days.
- For the month of November the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station: Staff has been checking all equipment on a regular basis. The blower unit on the mini phoenix is been fixed and put back on. Some of the ARV valves have been closed in that area as well. They are believed to be causing some of the odor problem in that area.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of short Staff and work load on doing inspections for the District.



Nov. 2021 plant
activities.doc

- We have hired two Collections workers  Nov. 2021 plant activities.doc, Staff are training them, and Collections will soon be back to full force on cleaning and taking care of the system properly.
- WWTF Security camera equipment, start-up and installation system has been put out for bid. New security camera monitoring system for the Plant hopefully will be installed by the first of the year.
- Estimated Plant processed for the month of November was 39.1 MG.