

OLIVEHURST PUBLIC UTILITY DISTRICT, 2026

To: John Tillotson

From: Virgil Willard

Re: Monthly Report on Activities August 2026

1. Water Treatment Plants / Wells:

- WTP #4 / Well #1 – No operating issue. August total: 22.350 MG
- WTP #28 / Well #10 – No operating issues. August total: 13.701 MG
- Wheeler Ranch WTP Well #29 and #30 – No operating issues. August total: 61.557 MG
- Lindhurst Booster Pump Station – No operating issues.
- Plumas Lake WTP Well #31 and Well #32 – No operating issues. August total: 91.721 MG
- WTP #34 – The plant is online no operating issues. August total: 6.728 MG

2.

Total MG	2018	2019	2020	2021	2022	2023	2024	2025	2026
Jan	49.5	49.3	52.7	62.0	59.7	62.7	61.71	66.78	65.23
Feb	47.25	44.8	56.2	57.4	68.8	64.25	56.04	58.05	60.79
Mar	51.2	52.9	74.2	74.5	109.9	61.89	68.16	72.12	101.06
Apr	65.1	70.0	93.8	114.5	101.3	81.61	86.31	101.52	106.93
May	116.9	104.3	142.2	162.6	140	124.93	143.2	161.38	131.16
Jun	151.8	151.5	165.4	162.4	157	155.39	189.5	188.60	183.22
Jul	171.4	168.3	186.9	182.2	185	190.12	203.5	212.42	199.76
Aug	152.1	170.9	176.9	165.5	102	188.11	181.2	184.53	196.05
Sep	131.2	136.8	145.0	147.6	144	154.01	163.5	160.48	
Oct	105.2	117.2	132.3	109.3	125	117.66	148.0	109.01	
Nov	80.7	91.2	83.3	62.2	42	82.658	80.90	72.589	
Dec	53.5	60.5	62.3	58.3	62	71.571	76.46	56.064	

The pumping report will be a month behind

3.

Water Wells	Static August	Static September	Op August	Op September	Setting	GPM
Well #1	42ft	32ft	56ft	48ft	140ft	1500
Well #4	52ft	35ft	76ft	65ft	140ft	2200
Well #10	30ft	32ft	66ft	48ft	160ft	1500
Well #28	30ft	34ft	44ft	76ft	200ft	1250
Well #29	39ft	33ft	185ft	222ft	252ft	2420
Well #30	32ft	33ft	112ft	105ft	190ft	3000
Well #31	28ft	34ft	30ft	38ft	330ft	2450
Well #32	42ft	38ft	145ft	138ft	180ft	2900
Well #34	26ft	26ft	68ft	68ft	200ft	1600

4. For the month of August and September the distribution system and water treatment plants met all requirements.

5. Water Distribution Repairs

6. Radio Read Meters

- 40 meter locations on MXUs have been tested and repaired
- 0 flow checks evaluated and discussed with customers

Below is a list of repairs/expenditures recognizing failure after the monthly meter read.

September meter repair is \$3,750. The meter expenditure will be an addition to all monthly Water Department reports.

- 150 locations on Non-Consumption list repaired as necessary
- 10 MXU replaced (10 x \$165) = \$1,650
- 20 registers replaced (20 x \$75.00) = \$1,500
- 15 chambers replaced (15 x \$40.00) = \$600

7. Meter Program 0 flat rate services.

8. Water service shut off for non-payment 80

9. District Subdivision and other projects

- a. August/September finals:
 - Plumas Lake – 20
 - Olivehurst – 4