

OLIVEHURST PUBLIC UTILITY DISTRICT

Our mission is to provide high quality services to enhance our community's quality of life.



GENERAL MANAGER
John C. Tillotson

March 03, 2022

OLIVEHURST COMMUNITY PARK REBID – SPRAY PARK

Addendum 1

To All Bidders,

The following questions have been brought to OPUD attention at the mandatory meeting and we wanted to share with all the bidders present (either in previous mandatory meeting held on 01/27 for first round bid or recent mandatory meeting for all others on 03/03) regarding responses in order for everyone to be aware, refreshed, and up-to-date. Please see questions below along with remark in **green**.

1.) : Who is the contact for equipment?

A: Jonathan Rainbolt at Playground
jonathan@playgroundpros.com

2.) Are we going to cover temporary facilities or will OPUD cover, specifically bathrooms?

A: Facilities in the Youth Center Building, next to the pool, can be used during the project.

3.) Will we need perimeter fencing?

A: Yes.

4.) Where is there access to the property?

A: We will make access. We have gates that can be opened to allow for access. Please contact the front office at OPUD and notify Engineer prior to conducting any work at a minimum 24 hours. Access to the project area is on both 9th and 10th Avenues.

5.) What is the timeline? ASAP? The driving factor will be how long it will take to get the equipment?

A: We would like to have the project completed by the first week of June, if possible but understand the time it takes for materials to arrive due to the Pandemic and shortages of supply and no set specific date will be required.

6.) Are we going to be responsible for relocating the existing park irrigation in the area?

A: We will cap the irrigation off. It is okay to dig up the existing irrigation in the area.

7.) Will we need to supply our own electrical panel or subpanel?

A: There is a transformer that you can tie into for electrical. We are not 100% positive there is enough amperage to the pool panel to run both the pool and splash pad at the same time.

8.) Where is the water connection?

A: The backflow lies near the pool deck, close to the gated fence area, just north of the project Splash Pad.

9.) Are we in charge of the plan and development fees??

A: Yes

Regards,



Swarnjit Boyal,
Public Works Engineer