

# OLIVEHURST PUBLIC UTILITY DISTRICT, 2026

To: John Tillotson

From: Virgil Willard

Re: Monthly Report on Activities March 2026

1. Water Treatment Plants / Wells:

- WTP #4 / Well #1 – No operating issue. March total: 26.358 MG
- WTP #28 / Well #10 – No operating issues. March total: 0.087 MG
- Wheeler Ranch WTP Well #29 and #30 – No operating issues. March total: 21.903 MG
- Lindhurst Booster Pump Station – No operating issues.
- Plumas Lake WTP Well #31 and Well #32 – No operating issues. March total: 35.194 MG
- WTP #34 – The plant is online no operating issues. March total: 17.520 MG

2.

Total MG	2018	2019	2020	2021	2022	2023	2024	2025	2026
Jan	49.5	49.3	52.7	62.0	59.7	62.7	61.71	66.78	65.23
Feb	47.25	44.8	56.2	57.4	68.8	64.25	56.04	58.05	60.79
Mar	51.2	52.9	74.2	74.5	109.9	61.89	68.16	72.12	101.06
Apr	65.1	70.0	93.8	114.5	101.3	81.61	86.31	101.52	
May	116.9	104.3	142.2	162.6	140	124.93	143.2	161.38	
Jun	151.8	151.5	165.4	162.4	157	155.39	189.5	188.60	
Jul	171.4	168.3	186.9	182.2	185	190.12	203.5	212.42	
Aug	152.1	170.9	176.9	165.5	102	188.11	181.2	184.53	
Sep	131.2	136.8	145.0	147.6	144	154.01	163.5	160.48	
Oct	105.2	117.2	132.3	109.3	125	117.66	148.0	109.01	
Nov	80.7	91.2	83.3	62.2	42	82.658	80.90	72.589	
Dec	53.5	60.5	62.3	58.3	62	71.571	76.46	56.064	

The pumping report will be a month behind

3.

Water Wells	Static March	Static April	Op March	Op April	Setting	GPM
Well #1	36ft	30ft	65ft	72ft	140ft	1500
Well #4	44ft	32ft	67ft	52ft	140ft	2340
Well #10	30ft	28ft	62ft	78ft	160ft	1500
Well #28	24ft	26ft	40ft	100ft	200ft	1100
Well #29	21ft	24ft	172ft	167ft	252ft	2400
Well #30	20ft	28ft	94ft	105ft	190ft	3000
Well #31	22ft	26ft	22ft	Naft	330ft	2980
Well #32	34ft	34ft	140ft	140ft	180ft	3120
Well #34	12ft	12ft	50ft	50ft	200ft	790

4. For the month of March, the distribution system and water treatment plants met all requirements.
5. Water Distribution Repairs
6. Radio Read Meters

- 75-meter locations on MXUs have been tested and repaired
- 0 flow checks evaluated and discussed with customers

Below is a list of repairs/expenditures recognizing failure after the monthly meter read. February meter repair is \$4,575. The meter expenditure will be an addition to all monthly Water Department reports.

- 0 locations on Non-Consumption list repaired as necessary
- 25 MXU replaced (25 x \$165) = \$4,125
- 6 registers replaced (6 x \$75.00) = \$450
- 0 chambers replaced (0 x \$40.00) = \$0

7. Meter Program 0 flat rate services.
8. Water service shut off for non-payment – 80
9. District Subdivision and other projects
  - a. March/April finals:
    - Plumas Lake – 22
    - Olivehurst – 4